

EQUIPMENT SCHEDULE

EOPM #	ROOM #	DESCRIPTION	NEW	QTY	BRAND	VOLT/HZ/PHASE	AMPS	TYPE	D *W *H*	WATER SUPPLY	DRAIN	INSTALLED BY	REMARKS
1	118	SPECTROMAXPLUS 384		1	MOLECULAR DEVICES	120V/60HZ/1Ø	4A		25 *41 *22"			OWNER	
2	118	325°C OVEN		1	VMR	120V/60HZ/1Ø	14A DED		28 *26 *42"				
3	118, 125	LABONCO FUME HOOD	2X	4	VMR	120V/60HZ/1Ø	10A DED		35 *22 *82"				1 FUTURE HOOD PROPOSED. NEEDS FANS, VTR. ELECTRICIAN TO MOUNT ON FUME HOOD & OWNER TO BLOWER
	118, 125	BLOWER FOR HOOD #3 (7181400)	2X	4	LABONCO	208V/60HZ/1Ø	5.8A		16.75 *24.5 *28.8"			ELECTRICIAN	
4	118	65°C FLOOR AIR SHAKER (INNOVA 43)		1	NEW BRUNSWICK SCIENTIFIC	120V/60HZ/1Ø	20A DED CIRCUIT		32 *46 *66" (LID OPEN) 28 *26 *35" (LID OPEN)				THERE SHOULD BE 5" BEHIND & 8" BETWEEN
5	118	REFRIGERATED CENTRIFUGE (4K150)		2	SIGMA	240V/60HZ/1Ø	16A DED	UNIVERSAL					
6	118	REFRIGERATED CENTRIFUGE (58109)		2	EPPENDORF	120V/60HZ/1Ø	12A DED		24 *28 *13"				
7	118	SEED CRUSHER		1	CUSTOM	115V/60HZ/1Ø	13.2A DED		32 *38 *49"				
8	118	MAXI MIX III (TYPE 65800)		1	THERMOLAB	120V/60HZ/1Ø	0.4A		10 *14 *10"				
9	118	REFRIGERATOR (SIDE X SIDE)		1	AMANA	120V/60HZ/1Ø	15A DED		32 *36 *68"				
10	118, 119	-20°C EXPLOSION PROOF FREEZER		2	LAB LINE	115V/60HZ/1Ø	4.5A	USE J-BOX	30 *32 *21"			ELECTRICIAN	HARDWIRED W/ RATED J-BOX
11	118	4°C CHROMOTOSRAPH UNIT 3 DOOR	1X	2	FISHER SCIENTIFIC (SCIENTIF)	120V/50HZ/1Ø & 208V/60HZ/1Ø	14.5A DED	UNIVERSAL	36 *85 *29"				1 FUTURE PROPOSED
12	118	ICE MACHINE FLAKER (AF400)		1	SCOTTSMAN	115V/60HZ/1Ø	9.8A DED		24 *24.25 *39"	1/2" DIRRO 1/2" C	2" F.D.	PLUMBER	
13	118	SPEED VAC		1	SAVANT	240V/60HZ/1Ø	12A DED	UNIVERSAL	29 *36 *36" (LID OPEN) 19 *12 *23"				2 PER CIRCUIT
14	118	MICROCENTRIFUGE (Z233 M-2)		6	HERMLE	120V/60HZ/1Ø	6A		19 *12 *23"				2 PER CIRCUIT
15	117, 118, 124	STIRRING HOTPLATES PRECISION BALANCE (PB3002S)	6X	18	FISHER SCIENTIFIC (SCIENTIF)	120V/60HZ/1Ø	10A DED		VARIES				1 PER CIRCUIT
16	117, 118	PRECISION BALANCE (PB3002S)		2	METTLER-TOLEDO	120V/60HZ/1Ø	(6A)						2 PER CIRCUIT
17	118	WATER BATH (SHALLOW FORM SHAKING)		3	PRECISION	120V/60HZ/1Ø	8.3A		15 *25 *17"				2 PER CIRCUIT
18	118	MICROWAVE		1	KENMORE	120V/60HZ/1Ø	12.9A DED		17 *24 *15"				
19	118	2000 GENO/GRINDER	1X	3	SPEX GERTHREP	115V/60HZ/1Ø	10A DED		17 *21 *22"				2 PER CIRCUIT
20	119	PCR UNIT (M1-PTC10)		17	MJ RESEARCH	120V/60HZ/1Ø	4A		16 *12 *14" (LID OPEN)				2 PER CIRCUIT
21	119	PCR UNIT (M1-PTC20)		14	MJ RESEARCH	120V/60HZ/1Ø	6.3A		16 *16 *14" (LID OPEN)				2 PER CIRCUIT
22	119	DNA ENGINE DYAD		1	MJ RESEARCH	250V/60HZ/1Ø	12.6A DED	L2321, TWIST LOCK	22 *28 *13" (LID OPEN)				
23	119	-20°C FREEZER		1	WHIRLPOOL	115V/60HZ/1Ø	2A		32 *24 *61"				
24	119	4°C SLIDING GLASS DISPLAY REFRIGERATOR (ALEGRA 6)		1	VMR	120V/60HZ/1Ø	20A DED CIRCUIT		31 *64 *72"				w/ COMPUTER
25	119	PLATE CENTRIFUGE (GEMINI XS FLUOROMETER)		1	BECKMAN	120V/60HZ/1Ø	8A DED		29 *22 *33"				w/ COMPUTER
26	119	GEMINI XS FLUOROMETER		2	MOLECULAR DEVICES	120V/60HZ/1Ø	4A		30 *41 *22"				
27A	119	REAL-TIME PCR UNIT (7900 HT)		1	APPLIED BIOSYSTEMS	240V/60HZ/1Ø	16A DED	L2321, TWIST LOCK	33 *80 *25"				w/ COMPUTER
27B	125	REAL-TIME PCR UNIT (CFX96)	X	1	BIO-RAD	110V/60HZ/1Ø	7.5A		33 *49 *25"				w/ COMPUTER
28	119	PLATE SEALER (ALPS 3000)		1	THERMO SCIENTIFIC	120V/60HZ/1Ø	20A DED CIRCUIT		7.25 *16.25 *14.5"				
29	119	FREEDOM EVO ROBOT		1	TECAN	120V/60HZ/1Ø	10A DED		32 *82 *35"				FOR FREEDOM EVO ROBOT
30	119	COMPUTER STATION		1	HP	120V/60HZ/1Ø	20A DED CIRCUIT		30 *36"				BIOMER SETS UP INSIDE THE LAMINAR FLOW HOOD.
31A	119	LAMINAR FLOW HOOD & BIOMER 2000		1	NUVAR & BECKMAN	120V/60HZ/1Ø	8A DED & 20A DED		34 *24"				HOSPITAL GRADE PLUG
31B	123, 124	BENCH	X	4	THERMO SCIENTIFIC	120V/60HZ/1Ø	12A DED	NEMA 5-1ØP	34 *24"				
31C	123	BIOSAFETY CABINET CLASS II	X	1	THERMO SCIENTIFIC	115V/60HZ/1Ø	20A DED	NEMA 5-2ØP	31.3 *74.9 *69.8"				
32	120, 121, 122	PLATFORM ORBITAL SHAKERS	X	3	NEW BRUNSWICK SCIENTIFIC	120V/60HZ/1Ø	1.25A		24 *36 *24"				
33	123	EXPLSION PROOF REFRIGERATOR/FREEZER	X	1	FISHER SCIENTIFIC (SCIENTIF)	115V/60HZ/1Ø	15A DED		24.5 *23.5 *65"				
34	123	-20°C FREEZER	X	1	FISHER SCIENTIFIC (SCIENTIF)	115V/60HZ/1Ø	(15A) DED		28.5 *32 *10.25"				
35	123, 125	4°C THREE HINGED GLASS DOOR FRIDGE	X	3	VMR	115V/60HZ/1Ø	15A DED		29.5 *28 *29.25"				
36	123	LAB OVEN (13-247-6376)	X	1	FISHER SCIENTIFIC (SCIENTIF)	120V/60HZ/1Ø	11A DED		23.5 *25.75 *33"				
37	123	AVO SCOPE A1 MICROSCOPE	X	1	CARL ZEISS	110V/60HZ/1Ø	(1.8A)		20 *20"				
38	123	REFRIGERATED INCUBATOR	X	1	FISHER SCIENTIFIC (SCIENTIF)	115V/60HZ/1Ø	6A		25 *24 *35"				
39	123, 124	DIGITAL CIRCULATING WATER BATH	X	2	THERMO SCIENTIFIC PRECISION	120V/60HZ/1Ø	12.9A DED		14 *37 *10"				
40	123, 125	MICROWAVE	1X	2	LOCAL STORE	115V/60HZ/1Ø	(13A) DED		20 *23 *15"				
41	124	BARCODE PRINTER	X	1	MICROLOGY INTERNATIONAL	120V/60HZ/1Ø	60VA		15 *9 *16"				
42	124	SYSTEC MEDIAPREP 20	X	1	MICROLOGY INTERNATIONAL	208V/60HZ/3Ø	20A DED CIRCUIT	L142ØP	22 *26 *30"	1/2" C, 1/2" DIRRO	2" DRAIN @ 49" A.F.F.	PLUMBER/TECHNICIAN	WASHER BOX IN WALL
43	124	MEDIALET	X	1	MICROLOGY INTERNATIONAL	120V/60HZ/1Ø	(15A) DED		26 *25 *35"				
44	124	TOPLOADING BALANCE	X	1	DENVER INSTRUMENT	115V/60HZ/1Ø	(0.035A)		15 *10 *4"				
45	124	ANALYTICAL BALANCE	X	1	DENVER INSTRUMENT	115V/60HZ/1Ø	(0.035A)		14.5 *9.5 *13.25"				
46	124	MILLI-Q INTEGRAL WATER PURIFICATION SYSTEM	X	1	MILLIPORE	115V/60HZ/1Ø	22A DED CIRCUIT		19 *13.1 *19.7"	1/2" DIRRO, 1/2" C, W/ VALVE @ 44" A.F.F.	2" @ 19.5" A.F.F. (LEFT SIDE)	OTHERS/TECHNICIAN	WALL MOUNTED UNIT W/ WATER SELECTION
47	124	DISHWASHER (G78634E)	X	1	MIELE PROFESSIONAL	240V/60HZ/3Ø	20A DED CIRCUIT	4 WIRE TWIST LOCK	23.5 *3.5 *33.5				

Approved by
Boyer
CropScience
Santa Fe 32
LP
LTD.

SHADED BOXES DENOTE CHANGES IN EQUIP. SCHED.

Wilkerson
PROPERTIES INC.
Commercial & Industrial
Development, Management & Brokerage
Phone: (806) 474-2223
Fax: (806) 474-2216
501 E. 66th Street
Lubbock, Texas 79404

SANTIA FE PARK - LOT32 - SUITE 500
6112 43rd Street
Lubbock, Texas 79407
Date: 10/24/2008
Drawn by: JMT, JMS, MRK
Checked by:

Rev: 11/17/2008

Notes:

A7a